inFIRE CONFERENCE 2008

FIRES, SAFETY, AND INFORMATION UNITING THE PIECES

HOSTED BY SAFETY ENGINEERING LABORATORIES, INC. OMNI DETROIT HOTEL AT RIVER PLACE

MAY 5-8, 2008

Damage To Consumer Appliances' and Electronics' Transformers and Fuses Under Simulated Fire Conditions

> Safety Engineering Laboratories, Inc. Donald Hoffmann, Ph.D., P.E., C.F.I. Presented by Erik Swonder, MSEE



The International Network for Fire Information and Reference Exchange







• Fuses



• Transformers







Electronic Devices in the Area of Origin Often become Focus of Investigation











Research Helps Identify or Eliminate Electronic Devices in the Course of the Investigation





Research Also Provides New Tools To be Used in Investigations





Fuse Testing

- Fire Damage to Electronic Devices
- Fuses and their Operation
- Forensic Examination of Fuses
- Test Conditions
- Gross and Microscopic Damage to fuses





Fuses from Fire Tests







7





FUSES

An overcurrent protective device with a circuit-opening fusible part that is heated and severed by the passage of overcurrent through it. (IEEE Std 100-1972)







NFPA 921 on Fuses

• 24.5.2.4.1:

"The fusing element in a fuse can be one of several metals. In all fuses the element has the proper cross section and electrical resistance for the temperature to rise to the melting point if current exceeds a specific level for a specified duration. If the excess current is moderate (e.g., less than twice the rating), the fuse element will melt without vaporization. If the current is very high, as with a dead short, the element will usually partly vaporize to give an opaque deposit on a window or glass tube of the fuse."





FUSES

- Circuit protection devices
- Highly engineered
- Different:
 - Sizes and construction
 - Voltage and current ratings
 - Response time
 - Secured differently







20 mm Glass Fuses

- Found in small electronic devices (TVs, VCRs, printers, etc).
- 3 Amp Slow Blow and Fast Acting fuses with tin coated copper fuse elements



Slow Blow



Fast Acting





Operation of Fuses

- 'Fail-safe' and irreversible
- Temperature dependent
 - Melting temperature of element
 - Ambient conditions
- Conditions
 - Overcurrent
 - Overload
 - Fatigue





Fuse Opening from Overcurrent

150%

200%













Forensic Examination of Fuses

- Electrical Continuity
- X-ray Examination
- Gross appearance
 - Element condition
 - Staining on the glass case
- Challenges
 - Embedded in plastic
 - Dark discoloration
 - Non-destructive







Fuse Testing

- 16 different 1-6.3 amp 20 mm glass fuses
- 12 Conditions of current and intense heat
- Examination of damage
 - Gross
 - Microscopic













Test Conditions

- 12 Conditions of current and heat
 - 50%, 100%, 150% and 200% of the rated current
 - Energize at ambient conditions then expose to heat
 - Energize simultaneous with exposure to heat
 - Intact and broken glass exposed to heat (i.e., no electrical history)





Heat Exposure



Max Heat Flux = 39 kW/m^2 Temperature = up to 1400 F(760 C)





Preliminary Results

- Discoloration
 - Heat exposure resulted in uniform discoloration but varied in intensity
 - Opened electrically resulted in a ring, spot or band but varied in intensity
- Location of open ends of element
 - Both symmetric and asymmetric with respect to the center of the fuse





Discoloration



Opened electrically



Heat exposure



• Possible locations of the ends of a Fast Acting fuse element







Duration of Continuity

Depends on temperature and construction

FUSE	Fuse Response	50% (sec)	150% (sec)	200% (sec)	50% + heat (sec)	100% + heat (sec)
5MF3	Fast	>300	2.3-5.7	0.3-1.0	30.5-160.3	16.7-31.7
5TT3	Slow	>300	26-203.3	5.3-7.2	21-106.3	9.0-20.3

5MF3 Fuse secured by solder and crimping. 5TT3 fuse element secured by solder only. Typical solder melts at ~150-200 S ℃





SEM Examination

- Parting arc (bright flash)
- T>T_m Cu = 1983°F (1084°C)
- Rapid cooling
- Did not vaporize completely
- Localized damage to glass fibers of slow blow fuse





use 6MF3 Test 3B

⊢ 200 µm ⊣ Fuse 6MF3 Test 3B

⊢20 µm





Fuse 6TT3 Test 3B

Fuse 6TT3 Test 3B

- 500 µm ----







Results of Fuse Testing

- 1) Opened electrically at ambient conditions when the current exceeded the rated current;
- 2) Opened electrically at the rated current but higher than ambient temperatures
- 3) May lose continuity due to a melted element when they are both energized at or below the rated current <u>and</u> exposed to temperatures typical of fire environments, and
- 4) May lose continuity due to loss of solder when they are either energized or non-energized and also exposed to temperatures typical of fire environments (T ~ 1400°F).





Conclusions

- An open fuse can result when an energized device is exposed to an external fire.
- Fuses melt/open under certain conditions of current and heat.





- Testing of energized and non energized transformers was conducted
- Testing included inducing faults in the Primary under heated and ambient temperatures and evaluating the damage
- The primary winding thermal fuse was disconnected for purposes of testing transformers not thermally protected





- Transformer Characteristics
 - Primary Input
 - 120V, 60 Hz
 - Rated Output
 - 9.8V_{dc}, 2.0 A (with an associated rectifier)







• Transformer Wiring Diagram







• Transformer Cross Section









• Transformer characteristics







- Testing
 - Heated not energized (oven and gas burner)
 - Heated energized at rated load (oven and gas burner)
 - Internal Heating (no external heat)
 - Internal Heating with external heat (gas burner)
 - Internal heat Thermal Protection not bypassed.









Transformer Damage

• Internal heating, Oven 600F, Fire Exposure







• Heated not energized







Heated operating at rated load

TEST 3 : External Heat Exposure (oven) - Energized with rated load







• Internal Heating with Thermal Fuse

Test 8: Internal Heating with Thermal Fuse In Circuit (0.5 ohm sec. load)







• Internal Heating







• Heated at rated load









• Heated at rated load









• Internal Heating









Transformer Unwinding







Transformer Unwinding







- External Heating Not Energized
 - Resistance measurements indicated shorting in primary and secondary windings
 - Unwound
 - No discontinuities in windings
 - No localized melting/fusing between windings





- External Heating Energized Rated Load
 - Resistance measurements all open (Primary)
 - Unwound
 - Localized arcing found between winding layers











- Internal Heating
 - Fuse bypassed
 - Arcing found mostly on inner most layers
- Internal Heating in Fire
 - Fuse bypassed
 - Arcing on multiple layers from outside in







• Summary of Testing

CEA Transformer - Summary of Unwinding Examination

Test	Type of Heating	External Heat Source	Post-test evaluation of Primary Winding start and finish leads to Pins 1-4	Evid. of electrical activity found during unwinding process
1	External Heat Exposure Not Energized	Air-circulating Oven 600F	All primary leads intact to Pins 1-4	Unit 10 - NO E.A. Unit 11 - NO E.A.
2	External Heat Exposure Not Energized	Natural Gas Burner	Evaluation incomplete because of damage to the brittle winding lead wires after fire exposure	Unit 33 - NO E.A. Unit 36 - NO E.A.
3	External Heat Exposure Energized with Rated Load	Air-circulating Oven 600F	Each unit had 1 or more primary leads fused (OPEN) near Pins 1-4	Unit 13 - E.A. on layer 3 Unit 16 - NO E.A. Unit 17 - NO E.A. Unit 21 - E.A. on layers 2-7
4	External Heat Exposure Energized with Rated Load	Natural Gas Burner	Evaluation incomplete because of damage to the brittle winding lead wires after fire exposure	Unit 43 - E.A. on layers 6-7 Unit 44 - E.A. on layers 2-6 Unit 49 - NO E.A. Unit 50 - E.A. on layers 1-6
5	Internal Heat Energized with 0.5 ohm load	N/A	Each unit had 1 or more primary leads fused (OPEN) near Pins 1-4	Unit 24 - E.A. on layer 7 Unit 25 - NO E.A. Unit 28 - E.A. on layer 7 Unit 31 - E.A. on layer 6
6	External Heat Exposure while Internally Heating Energized with 0.5 ohm load	Natural Gas Burner	Evaluation incomplete because of damage to the brittle winding lead wires after fire exposure	Unit 53 - E.A. on layers 2-5 Unit 56 - NO E.A. Unit 57 - E.A. on layers 2 & 4 Unit 59 - E.A. on layers 2-6
7	Internal Heating Energized with 0.5 ohm load followed by External Heat Exposure	Natural Gas Burner	Evaluation incomplete because of damage to the brittle winding lead wires after fire exposure	Unit 64 - E.A. on layers 1-4 Unit 68 - NO E.A. Unit 69 - E.A. on layers 4, 6-7 Unit 73 - E.A. on layer 6
8	Internal Heating Energized with 0.5 ohm load (with thermal fuse in circuit)	N/A	All primary leads intact to Pins 1-4	Thermal fuse OPENED & post-test winding resistance measurements were unchanged, therefore, unwinding was unnecessary

E.A. - Evidence of electrical activity

Note: Thermal fuse was removed from circuit and replaced with a wire on ALL transformers in Tests 1-7.





• Summary of Testing







- Conclusion
 - Internal heating typically produced inner winding faults
 - External heating energized produced faulting throughout windings.
 - Location of electrical activity does not necessarily indicate failure mode





- Conclusion
 - Lack of Fusing of primary leads indicates the transformer was not energized at the time of fire attack.
 - Fusing of the primary leads does not indicate transformer failed and caused fire but does indicate it was energized during the fire.





- Conclusion
 - Internal Heating worst case did not ignite materials of transformer even when thermal fuse was bypassed.
 - Transformer failed during internal heating without ignition of combustibles.





Acknowledgements







Thank you for your attention! Donald J. Hoffmann, Ph.D. Erik Swonder, MSEE Safety Engineering Laboratories, Inc. 27803 College Park Drive, Warren, MI 48088 Email: donh@safetyengineeringlabs.com eriks@safetyengineeringlabs.com Website: www.safetyengineeringlabs.com Phone (586) 771-0660

